

**Akhalsikhe-Borcka 400 kV HV interconnection line**  
**NTC/ATC values for year 2017**

Utilization Periods (Month/year)	NTC		AAC	ATC
	Export Direction			
	From Georgia to Turkey	Form Turkey to Georgia	From Georgia to Turkey	From Georgia to Turkey
January 2017	700 MW	700 MW	0.0	700.0
February 2017	700 MW	700 MW	0.0	700.0
March 2017	100 MW	700 MW	37.7	62.3
April 2017	100 MW	700 MW	65.6	34.4
May 2017	250 MW	700 MW	88.5	161.5
June 2017	300 MW	700 MW	74.7	225.3
July 2017	700 MW	700 MW	46.2	653.8
August 2017	700 MW	700 MW	39.3	660.7
September 2017	700 MW	700 MW	38.0	662.0
November 2017	700 MW	700 MW	38.0	662.0
October 2017	700 MW	700 MW	38.0	662.0
December 2017	700 MW	700 MW	0.0	700.0

- NTC values may be decreased to 35 MW according to system conditions and will be determined by Dispatching Centers of both countries 1 day before electricity transit start.
- Akhalsikhe S/S HVDC equipment minimum transferable capacity is 35.2 MW for each 350 MW unit.